

**Phase 2 Report**  
**Mississippi Mills Water and Wastewater Infrastructure Master Plan**

---

---

**Appendix E**

Wastewater Conveyance System  
Technical Memorandum  
(JLR, 2023)

**JLR No.: 29920-008**  
**Revision: 0**

**September 11, 2023**

Prepared for:

**MUNICIPALITY OF MISSISSIPPI MILLS**  
Box 400, 3131 Old Perth Rd  
Almonte, ON  
K0A 1A0

Prepared by:

**J.L. RICHARDS & ASSOCIATES LIMITED**  
343 Preston Street, Suite 900 and 1000  
Ottawa, ON  
K1S 1N4

# **Wastewater Conveyance System Technical Memorandum**

## **Mississippi Mills Infrastructure Master Plan**



# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

### Table of Contents

---

1.0	Introduction .....	1
1.1	Background .....	1
2.0	Modelling Approach .....	3
2.1	Summary and Inputs .....	3
2.2	Flow Monitoring Areas .....	3
3.0	Flow Modeling and Calibration .....	5
3.1	Flow Monitoring Data Collection .....	5
3.1.1	Rainfall Data .....	5
3.1.2	Dry Weather Flow (DWF) .....	5
3.1.3	Wet Weather Flow (WWF) .....	7
4.0	Design Criteria and Level of Service .....	14
5.0	Existing Conditions .....	15

### List of Figures

---

Figure 1: Existing Wastewater System .....	2
Figure 2: Study Flow Monitoring Locations .....	4
Figure 3: Rainfall Monitoring Results compared with Environment Canada IDF curve .....	5
Figure 4: Peak Flow Calibration Graph – July 18 Event .....	9
Figure 5: Volume Calibration Graph – July 18 Event .....	9
Figure 6: Peak Flow Calibration Graph – July 24 Event .....	10
Figure 7: Volume Calibration Graph – July 24 Event .....	10
Figure 8: Peak Flow Calibration Graph – August 8 Event .....	11
Figure 9: Volume Calibration Graph – August 8 Event .....	11
Figure 10: Peak Flow Validation Graph .....	13
Figure 11: Volume Validation Graph .....	13
Figure 12: Existing System Level of Service .....	16

### List of Tables

---

Table 1: Flow Monitoring Locations .....	6
Table 2: Flow Monitoring Characteristics .....	6
Table 3: Recorded Flows per Capita .....	7
Table 4: Wet Weather Calibration Events .....	8
Table 5: Monitored Wastewater System Flows .....	14
Table 6: Design Criteria Future Wastewater Flow Generation .....	15

### List of Appendices

---

Appendix A: Electronic Files

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

### 1.0 Introduction

---



#### 1.1 Background

The Municipality of Mississippi Mills completed a Water and Wastewater Master Plan in 2012, in accordance the Municipality Engineers Association (MEA) Class EA master planning process, for the Almonte Ward, one of three Wards found in the amalgamated Municipality. The Master Plan was subsequently updated in 2018 to reaffirm the preferred servicing alternatives to ensure the system can be relied on based on community growth and completed projects since the original Master Plan in 2012. Since then, changes within the municipality have initiated a request for an updated Water and Wastewater Infrastructure Master Plan for the Almonte Ward to reflect these new changes. The ultimate objective of this Infrastructure Master Plan (IMP) is to develop water and wastewater servicing strategies that align with updated growth projections. The intent of this IMP is to follow Approach No.1 within the remit of the project.

The Municipality of Mississippi Mills is located along Highway 49, approximately three kilometres from the City of Ottawa limits or 46 kilometres from its downtown core. The settlement of Mississippi Mills is bisected by the Mississippi Mills River. The community is serviced by a wastewater conveyance system that consists of 11 kilometres of gravity sewer, 130 meters of pressure sewer, one main pump station and a single wastewater treatment plan (WWTP) that provides secondary treatment and disinfection to wastewater prior to discharging into the Mississippi River (Figure 1).

This Technical Memorandum sets out the work undertaken to assess the current wastewater sewer system in terms of capacity and level of service. A calibrated dynamic sewer system model has been developed based on flow monitoring data undertaken for the project. The model provides an assessment of the status of the existing network. The overall sewershed area of the model, which represents the serviced extents of the Mississippi Mills community, is 370 hectares and currently holds a population of 6,098 residents.

N



- Legend**
- Sanitary Trunk Sewers
  - Local Sanitary Sewers

PROJECT:		<b>MISSISSIPPI MILLS MASTER PLAN UPDATE</b> ALMONTE, ONTARIO	
DRAWING:		<b>EXISTING WASTEWATER SYSTEM</b>	
 <b>J.L. Richards</b> <small>ENGINEERS · ARCHITECTS · PLANNERS</small>	This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without express written consent of J.L. Richards & Associates Limited.		DESIGN: ML
			JLR NO: 29920-008
			DRAWING NO: <b>Figure 1</b>
		CHECKED: BP	

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

### 2.0 Modelling Approach

---

#### 2.1 Summary and Inputs



PCSWMM was used for modeling of the sanitary sewer collection system. PCSWMM uses the EPA SWMM computational simulation engine and has a GIS based graphical user interface for data input and analysis.

The base sewage flows and infiltration components of SWMM operates on a collection of subareas that generate sewage flow inputs. The routing portion of SWMM transports this flow through a system of pipes, pump stations and other flow conveyance infrastructure. SWMM tracks the quantity generated within each subarea and the flow rate and flow depth of water in each pipe during a simulation period that is comprised of multiple time steps.

The system network was entered into the model based on available GIS data, additional as-constructed drawings, and discussions with the Municipality. Electronic model files are contained in Appendix A.

#### 2.2 Flow Monitoring Areas

Each flow monitor has an upstream sewershed area from which all sanitary flows entering the system are captured by the monitor. The sewersheds for the flow monitors in this project are as shown in Figure 2, along with the key infrastructure components including the Spring Street Pump Station and the Wastewater Treatment Plant (WWTP). These flow monitors have been installed at the downstream manholes of trunk sections of the sanitary pipe network. To cover a majority of the study area, seven monitors were strategically placed to account for the majority of flows while not being subject to backwater from the downstream system.



- Legend**
- Sanitary Trunk Sewers
  - Monitoring Locations
  - Subcatchments
  - Monitoring Sewersheds**
  - 1
  - 2
  - 3
  - 4
  - 5
  - 6
  - 7
  - NMA

PROJECT:		<b>MISSISSIPPI MILLS MASTER PLAN UPDATE</b> ALMONTE, ONTARIO	
DRAWING:		<b>STUDY FLOW MONITORING LOCATIONS</b>	
<b>J.L. Richards</b> <small>ENGINEERS · ARCHITECTS · PLANNERS</small>	This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without express written consent of J.L. Richards & Associates Limited.		DESIGN: ML
			JLR NO: 29920-008
			DRAWING NO: <b>Figure 2</b>
		CHECKED: BP	

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

### 3.0 Flow Modeling and Calibration


#### 3.1 Flow Monitoring Data Collection

##### 3.1.1 Rainfall Data

The rain data monitoring was carried out for a two-month period starting June 29, 2022, and finishing on August 31, 2022.

During the monitoring period, 20 wet weather events were identified. The highest intensity peak rainfall recorded was 54.86 mm/hr in 5 minutes on August 7th, 2022, which compares with a peak 5-minute intensity during a 1:2-year event of 125 mm/hr according to the Environment and Climate Change Canada (ECCC) intensity duration frequency (IDF) curve at the Ottawa Airport weather station. The event with the highest volume occurred over a 15-hour period starting in the afternoon of August 8, 2022, and 56.64 mm of rainfall accumulated over the duration of the storm. This is more than the 48.2 mm of rainfall expected during a 1:2-year event of similar duration. The events recorded during the monitoring period are graphed on Figure 3 along with the ECCC IDF curves and the peak 5-minute intensities during the events. Although the events are relatively small, they were considered sufficient for validation purposes.

**Figure 3: Rainfall Monitoring Results compared with Environment Canada IDF curve**



##### 3.1.2 Dry Weather Flow (DWF)

Flow monitoring was undertaken throughout the City's sanitary sewer system for the purposes of calibrating the dynamic simulation of the model. Flow monitoring was limited to seven locations across the sanitary sewer network over an approximate 2-month period between the end of June 2022 and the beginning of September 2022. The seven sites are shown in Figure 2 and are listed in Table 1 below.



# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

**Table 1: Flow Monitoring Locations**

Flow Monitor	Manholes	Final Location Address	Final Location Closest Intersection
FM01	SA3MH-307	224 Bridge Street	Bridges Street at Parkview Boulevard
FM02	SA3MH-005	29 Farm Street	Farm Street at Charles Street
FM03	SA1MH-003	300 Almonte Street	Almonte Street at Malcolm Street
FM04	SA2MH-114	25 Union Street North	Union Street North at Princess Street
FM05	SA2MH-207	24 Martin Street North	Martin Street North at Victoria Street
FM06	SA4MH-465	70 Clyde Street	Clyde Street at Brougham Street
FM07	SA4MH-001	21 Spring Street	Ottawa Street at Spring Street

The seven flow monitoring locations were located on main trunk sewers with upstream catchment areas sufficiently large enough to collect flow to efficiently calibrate the model. The raw results from the flow monitoring are contained in Appendix A.

Population and parcel fabric was provided by the Municipality. The flow monitoring areas were cross-referenced with the parcel fabric to establish land usage within. The summary of land usage is presented in Table 2 below. Also included in the table is the remaining area which was not captured in any of the flow monitoring locations (noted as 'NMA' in the table).

**Table 2: Flow Monitoring Characteristics**

Flow Monitor	Net Sewershed Area (ha)	% Residential Land Use	% ICI Land Use	% Open Space
FM01	42.3	75%	22%	3%
FM02	45.5	74%	19%	8%
FM03	34.4	75%	15%	10%
FM04	14.8	90%	6%	4%
FM05	31.0	87%	7%	6%
FM06	74.4	69%	14%	17%
FM07	88.8	26%	40%	34%
NMA	37.0	55%	35%	10%
Total	368.3			

An analysis of the dry weather flows was carried out in PCSWMM to determine the daily dry weather flow patterns. The periods of dry weather and where no impacts of wet weather events were present on the system, were identified in the flow monitoring results. The PCSWMM software was used to create an average pattern of the recorded dry weather flows for each flow monitor for daily, hourly and weekend periods.

To determine the extent of dry weather inflow and infiltration it was assumed that at the low point in the dry weather flow pattern around 15% of the flow is from population loading and the remainder is from dry weather inflow and infiltration. The low point of the dry weather flow pattern is typically in the early morning when it is likely that only overnight operations such as laundries or manufacturing processes with low sanitary loading is operating. Table 3 summarizes the results of the dry weather analysis.

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

Table 3: Recorded Flows per Capita

Flow Monitor	Net Catchment Area (ha)	Average DWF Flow (l/s)	Dry Weather I&I (l/s/ha)	Dry Weather Peaking Factor
FM01	42.3	3.98	0.05	1.4
FM02	45.5	4.08	0.06	1.2
FM03	34.4	1.87	0.02	1.3
FM04	14.8	0.62	0.01	1.5
FM05	31.0	3.83	0.05	1.3
FM06	74.4	4.55	0.02	1.6
FM07	88.8	3.10	0.01	1.6
NMA	37.0	2.46	0.03	1.4
Total / Average	368.3	24.50	0.03	1.4

Based on a serviced population of 6,098 persons, the overall flow rate is around 250 l/cap/day in the system during dry weather. The overall dry weather I&I is around 0.03 l/s/ha, which is lower than the design value of 0.05 l/s/ha used in the City of Ottawa.

The daily usage of the WWTP during the same period (June, July, August) in 2021 amounted to an average of 2,214 m<sup>3</sup>/day or 363 l/cap/day. Assessing the flow monitoring results over the entire period, including wet weather events, the average value is 304 l/cap/day. Therefore, these results support the flow monitoring as being consistent with the system as currently operating.

### 3.1.3 Wet Weather Flow (WWF)

The WWF calibration involves calibrating the rainfall dependent inflow and infiltration (RDII) in the model sewer system to enable the simulation of the response to the wet weather events. There is usually an initial short-term response due to any inflow from cross connections or similar. The medium term and long-term responses are from infiltration and act over a longer period after the storm.

To calibrate to each flow monitoring site, the upstream catchment nodes are assigned an inflow unit hydrograph which represents the wet weather response in the system. The unit hydrograph is created using RTK values which represent the volume of inflow, time to peak and the ratio of the time of recession to the time to peak respectively. The RTK values for the short-, medium- and long-term responses are used for the calibration. The calibration process completed for this model have resulted in the final RTK values.

The calibration envelope to be achieved through the variation of the RTK values is outlined in the CIWEM (Chartered Institute of Water and Environmental Management) Urban Drainage Group Code of Practice for the Hydraulic Modelling of Sewer Systems. The CIWEM Urban Drainage Group guidance is referred to in calibration reports in Canada as well as internationally. The envelope criteria are for:

- The timing of the peaks and troughs should be similar having regard to the duration of the event.

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

- The peak flow rates at each significant peak should be in the range + 25% to - 15% and should be generally similar throughout the event.
- The volume of flow should be in the range +20% to -10%.

The Code suggests that at least two of three events are calibrated to, and a fourth event is used for validation of the calibration. The discussion on the rainfall during the flow monitoring period in Section 3.1 highlighted events of significance that occurred during the flow monitoring. These have been combined into four events for calibration purposes and listed in Table 4. The events were selected based on the level of response in the system as well as the size of the event.

The flow monitoring did not capture any 1:5-year return period storm events or greater and therefore the resulting calibration will be affected by the limited flow monitoring data collected during the period.

Calibration was carried out on sections of the model so that each flow monitoring location can be calibrated independently and the response from each area isolated to determine appropriate RTK values for the sewershed draining to the flow monitoring location.

The results of the calibration are shown in the graphs in Figure 4 thru to Figure 9. The results are shown in each graph at the calibration value of observed versus calibrated peak flow or volume for each flow monitoring location with the calibration envelope shown in a green shade.

**Table 4: Wet Weather Calibration Events**

Event	Start of Event	Calibration Period (hours)	Peak Intensity (mm/hr)	Total Volume (mm)
Calibration 1	July 18, 2022 9:00 am	35	15.2	36.8
Calibration 2	July 24, 2022 2:00 pm	33	27.4	22.4
Calibration 3	August 8, 2022 1:15 pm	55.75	48.8	56.6
Validation	August 22, 2022 2:20 pm	28.17	21.3	23.1

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

Figure 4: Peak Flow Calibration Graph – July 18 Event





Figure 5: Volume Calibration Graph – July 18 Event



# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

Figure 6: Peak Flow Calibration Graph – July 24 Event





Figure 7: Volume Calibration Graph – July 24 Event



# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

Figure 8: Peak Flow Calibration Graph – August 8 Event





Figure 9: Volume Calibration Graph – August 8 Event



# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

The graphs show that calibration to the events in July 18 and July 24 were not ideal, but a good calibration fit, within the green calibration envelope, was achieved for the August 8<sup>th</sup> event.

In the July 18 event, most peak flow calibrated values are significantly higher or slightly lower than observed with very few values within the green envelope. As for the calibrated volume values, most values are significantly higher than observed.

The reaction of the system to the event of July 24 is not entirely consistent. The July 24 event tended to have a higher or lower response to the event compared to the calibrated model but very little response falling within the green calibration envelope.

Seeing as though the calibration was focused on the largest of the events and closest to the design storm, it was deemed that the August 8<sup>th</sup> event was a good fit for calibration. In fact, this event's maximum rainfall attained 48.77 mm/hr and yielded the greatest response in comparison to other storms, some with greater rainfall such as the August 7<sup>th</sup> rainfall. The calibrated volume, for the most part, fell within the calibration envelope whereas the observed peak flows tend to be higher than the calibrated flows.

Validation of the calibration was carried out by running the August 22<sup>nd</sup> event on the complete model. The event on August 22<sup>nd</sup> had a peak intensity and overall volume slightly inferior to half of those from the August 8<sup>th</sup> event.

The results of the validation are shown in Figure 10 and Figure 11. For the validation of the peak flow, monitoring locations FM01, FM02 and FM03 recorded higher modelled peak flows than observed and FM06 and FM07 recorded lower modelled peak flows than observed however the remaining flow monitoring locations had peak flows within or close to the validation envelope.

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

Figure 10: Peak Flow Validation Graph





Figure 11: Volume Validation Graph





# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

The higher modelled volume from inflow and infiltration was present in monitoring locations FM01, FM05 and FM07 during the validation period. The lower modelled volume was present at FM03 and the volume at FM04 and FM06 were a good calibration fit. These three areas are furthest from the Mississippi river and had 14 days separating the validation storm from a previous significant storm meaning that the soils were drier and had more capacity to retain runoff and thus reduce inflow and infiltration into the system. At the monitoring location FM03 it is likely that the smaller intermittent storms had a greater impact on the area. The more forested/vegetated area and river boundary can lead to soils retaining water and humidity for longer periods of time.

### 4.0 Design Criteria and Level of Service

---

Wastewater generation patterns vary between municipalities. The variations are primarily influenced by the habits and characteristics of system users. Volume as well as diurnal patterns will tend to fluctuate depending on servicing requirements such as the size of the serviced population, type and extent of industrial lands and the condition of the existing infrastructure.

The Ministry of the Environment and Climate Change (MOECC) Design Guidelines for Sewage Works (MOE, 2008) have accounted for variations in flow generation by permitting acceptable ranges for design calculations. As a result of this flexibility, many municipalities in Ontario have set standard flow generation criteria for their jurisdiction. The set design flow is typically within the MOECC's accepted range; however, it is often based on the historical flows observed by the municipality.

The calibration process identified an average dry weather flow infiltration allowance, peaking factor, residential loadings, and ICI loadings. The values obtained through the calibration procedure were in line with the expectations compared to the current City of Ottawa and Mississippi Mills design criteria. The values obtained are summarized in Table 5 below.

**Table 5: Monitored Wastewater System Flows**

<b>Parameter</b>	<b>Residential Areas</b>
Average Daily Flow	185 L/c/day
Infiltration Allowance (DWF)	0.03 L/s/ha
Peaking Factor (DWF)	1.42

For future development areas the sizing requirements for extended water and wastewater system will be based on the generation rates in Table 6. In order to simulate a 24-hour period of wastewater loadings in the system, an hourly loading pattern will be used in the model. These hourly loading patterns will be based on the calibrated loading patterns created based on the flow monitoring.

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

**Table 6: Design Criteria Future Wastewater Flow Generation**

Parameter	Average Day Flow	Extraneous Flows	Peaking Factor
Residential	350 L/cap/day	0.33 L/s/ha	Monitored Pattern
Commercial	28,000 L/s/ha	0.33 L/s/ha	Monitored Pattern
Light Industrial	35,000 L/s/ha	0.33 L/s/ha	Monitored Pattern

It is understood that the existing network should not necessarily be expected to achieve the level of service required by new development areas. The existing network was constructed based on different design criteria which may not be consistent with the design criteria today. In recognition of differing design criteria, the age of some of the network and resources required to implement infrastructure upgrades, an attainable level of service has been defined for the Infrastructure Master Plan assessment. The attainable level of service will reduce risk for existing neighborhoods while being achievable within the resource limitations of the Municipality (e.g., budget and schedule). The expected level of service for this Infrastructure Master Plan seeks to achieve for the sanitary network is:


- **Flow Criteria:**
  - Free flow conditions in sewers during dry weather flow (DWF)
- **HGL Criteria:**
  - HGL to remain 1.8 meters below ground surface (provide 1.8 m freeboard) during 1:25 year event where there is a basement flood risk.
  - HGL to remain within 300 mm of the pipe obvert if the pipe is within 1.8 meters of the surface.

## 5.0 Existing Conditions

---

The model was tested for its capacity under existing conditions without initiating any upgrades or considering any future loading. Different scenarios were used to evaluate its efficiency starting with the DWF (Dry Weather Flow) event and followed by multiple storm events (5, 10, 25, 50 and 100-year with the 3-hour Chicago storm distribution). For this study the DWF and 25-year events will be assessed against the level of service criteria.

Operation of the system under dry weather flow is good with the required level of service being achieved across the trunk network. Under the 25-year event model 3 trunk manholes were identified with level of service issues: SA2MH-300, SA2MH-301 and SA2MH-236. The HGL in the system at these nodes in the 1:25 year event is such that there is a risk of basement flooding in connected properties. The system is illustrated in Figure 12.



**Legend**

- HGL within 1.8m of Surface
- Within Capacity

PROJECT: **MISSISSIPPI MILLS MASTER PLAN UPDATE**  
ALMONTE, ONTARIO

DRAWING: **EXISTING CONDITIONS WASTEWATER LEVEL OF SERVICE**

**JLR** J.L.Richards  
ENGINEERS · ARCHITECTS · PLANNERS

This drawing is copyright protected and may not be reproduced or used for purposes other than execution of the described work without express written consent of J.L. Richards & Associates Limited.

DESIGN: ML  
DRAWN: ML  
CHECKED: BP

JLR NO: 29920-008  
DRAWING NO: **Figure 12**

# Wastewater Conveyance System Technical Memorandum

## Mississippi Mills Infrastructure Master Plan

---

This report has been prepared by J.L. Richards & Associates Limited for the Municipality of Mississippi Mill's exclusive use. Its discussions and conclusions are summary in nature and cannot properly be used, interpreted, or extended to other purposes without a detailed understanding and discussions with the client as to its mandated purpose, scope, and limitations. This report is based on information, drawings, data, or reports provided by the named client, its agents, and certain other suppliers or third parties, as applicable, and relies upon the accuracy and completeness of such information. Any inaccuracy or omissions in information provided, or changes to applications, designs, or materials may have a significant impact on the accuracy, reliability, findings, or conclusions of this report.

This report was prepared for the sole benefit and use of the named client and may not be used or relied on by any other party without the express written consent of J.L. Richards & Associates Limited, and anyone intending to rely upon this report is advised to contact J.L. Richards & Associates Limited to obtain permission and to ensure that the report is suitable for their purpose.

J.L. RICHARDS & ASSOCIATES LIMITED

Prepared by:

Reviewed by:

Mathieu Lacelle EIT  
Civil Engineering Intern

Bobby Pettigrew P.Eng.,  
Associate, Senior Water Resources Engineer

**Wastewater Conveyance System Technical Memorandum  
Mississippi Mills Infrastructure Master Plan**

---

---

**Appendix A**

Electronic Files



Platinum  
member

[www.jlrichards.ca](http://www.jlrichards.ca)

#### Ottawa

343 Preston Street  
Tower II, Suite 1000  
Ottawa ON Canada  
K1S 1N4  
Tel: 613 728-3571  
[ottawa@jlrichards.ca](mailto:ottawa@jlrichards.ca)

#### Kingston

203-863 Princess Street  
Kingston ON Canada  
K7L 5N4  
Tel: 613 544-1424  
[kingston@jlrichards.ca](mailto:kingston@jlrichards.ca)

#### Sudbury

314 Countryside Drive  
Sudbury ON Canada  
P3E 6G2  
Tel: 705 522-8174  
[sudbury@jlrichards.ca](mailto:sudbury@jlrichards.ca)

#### Timmins

834 Mountjoy Street S  
Timmins ON Canada  
P4N 7C5  
Tel: 705 360-1899  
[timmins@jlrichards.ca](mailto:timmins@jlrichards.ca)

#### North Bay

501-555 Oak Street E  
North Bay ON Canada  
P1B 8E3  
Tel: 705 495-7597

[northbay@jlrichards.ca](mailto:northbay@jlrichards.ca)

#### Hawkesbury

326 Bertha Street  
Hawkesbury ON Canada  
K6A 2A8  
Tel: 613 632-0287

[hawkesbury@jlrichards.ca](mailto:hawkesbury@jlrichards.ca)

#### Guelph

107-450 Speedvale Ave. West  
Guelph ON Canada  
N1H 7Y6  
Tel: 519 763-0713

[guelph@jlrichards.ca](mailto:guelph@jlrichards.ca)

