

- NOTES:**
1. FOR FOUNDATION LAYOUT PLAN, SEE DWG# 2428-C101.
 2. FOR SECTION VIEW, SEE DWG# 2428-E102 & E103
 3. FOR BILL OF MATERIALS, SEE DWG# 2428-E104.
 4. FOR FENCE DETAILS, SEE DWG# 2428-E105.
 5. ALL BARBED WIRES PERIMETER FACE OUT, ONLY ALMONTE 1 & 2 MIDDLE FENCE BARBED WIRES IS STRAIGHT UP.
 6. ALL DIMENSIONS AS SHOWN ARE METRIC IN MILLIMETRE UNLESS NOTED OTHERWISE.

- LEGEND:**
- 44kV L. & T.S. - 44kV L.A. AND TERMINATION SUPPORT
 - 44kV T-R S. - 44kV 3Ø TRANS-RUPTER SUPPORT
 - 44kV B.S. - 44kV 3Ø BUS SUPPORT
 - 44kV C/V C. - 44kV 3Ø CT/VT COMBOS
 - 44kV D.S. - 44kV 3Ø DISCONNECT SWITCH
 - POLE 3 - 45FT CONCRETE POLE 44kV DEADEND POLE W/ FUSE, INS., L.A. & S.S.T.
 - POLE 2 - 45FT WOOD POLE 44kV DOUBLE DEADEND POLE WITH REVENUE METERING
 - POLE 1 - 45FT CONCRETE POLE 44kV DOUBLE DEADEND POLE
- R - RIGID SUPPORT
S - SLIDE SUPPORT

0	ISSUE FOR CONSTRUCTION	30/09/2024	EH	SB	KW
REV	REMARKS	DATE	DRAWN	CHECKED	APPROVED


ISSUE FOR CONSTRUCTION



BLACK & McDONALD LTD.
31 MILLMAN CRT.
SCARBOROUGH, ONT.
M1X 1G4
TEL: (416) 291-8200
FAX: (416) 291-2282

THIS DRAWING IS THE INTELLECTUAL PROPERTY OF BLACK AND McDONALD LIMITED AND IS NOT TO BE LOANED OR REPRODUCED IN ANY WAY WITHOUT THE WRITTEN CONSENT OF BLACK AND McDONALD LIMITED.

COMPASS ENERGY ALMONTE BESS					
ALMONTE 2 (Ø 98 MV BESS) SUBSTATION / BESS LAYOUT PLAN					
CLIENT DRAWING NUMBER					
DRAWING NUMBER	2428-E101	REVISION	0	SHEET	0001
DATE	07/04/2024	DRAWN	EH	CHECKED	SB
		APPROVED	KW	SCALE:	1:180



SUBSTATION/BESS LAYOUT PLAN